



NOTES:

1. ROMAN NUMERALS REPRESENT THE DISTANCE TO THE NEAREST FOOT, MEASURED PERPENDICULAR, FROM THE FACE OF THE MARKER POST TO THE CENTER OF THE FACILITY.
2. ALL MARKER POSTS MUST BE SET TRUE, FACING THE FACILITY.
3. AVOID SETTING MARKER POSTS ON PRIVATE PROPERTY OR IN TRAVELED WAY.
4. MARKER POSTS ARE NOT REQUIRED WHERE REFERENCES CAN BE INCISED ON PERMANENT CURBS.
5. MARKER POSTS FOR WATER AND SEWER SERVICE SHALL BE REDWOOD, S4S, "HEART STRUCTURAL" GRADE, F.O.H.C., PAINTED ONE PRIME COAT (STATE OF CALIF. SPEC. 52-G-01), AND 2 COATS OF WHITE EXTERIOR ENAMEL (STATE OF CALIF. SPEC. 58-G-06).
6. MARKER POSTS FOR RECYCLED WATER SHALL BE AS PER NOTE 5, EXCEPT POSTS SHALL BE PAINTED PURPLE.
7. SEE DRAWING G-4A FOR ROMAN NUMERAL CHART.

REV. 04/07

Dublin San Ramon Services District	DATE JUNE 1966
MARKER POST (4" x 4")	DESIGNED RLW
SIGNED COPY ON FILE AT DISTRICT OFFICE	DRAWING G-4