



VALVE BOX
WITH CAST IRON
TRAFFIC LID

NOTES:

1. A.C. PAVEMENT TO COMPLY WITH STREET PAVEMENT REQUIREMENTS.
2. FOR VALVE BOXES INSTALLED IN NON-TRAFFIC AREAS, CONCRETE COLLAR SHALL BE EXTENDED TO FINISH GRADE. SLOPE COLLAR TO DRAIN AWAY FROM LID.
3. RISER PIPE TO BE ONE CONTINUOUS PIECE, APPROVED PVC
4. VALVE BOX COVERS FOR RECYCLED WATER MAINS SHALL BE TRIANGULAR WITH "RW" INSCRIPTION CAST ON THE TOP SURFACE.

REV. 06/06

Dublin San Ramon Services District	DATE MAY 1987
VALVE BOX INSTALLATION	DESIGNED SAD
SIGNED COPY ON FILE AT DISTRICT OFFICE	DRAWING W-1