



ITEM	DESCRIPTION
A	3" FLG RESILIENT SEATING G.V. WITH 2" SQ. NUT, CLOSE CLOCKWISE
B	SCREW FLANGE
C	3" BRONZE NIPPLE
D	TRACER WIRE FOR PVC PIPE ONLY, TW TYPE #10
E	3" BRONZE 90° ELL
F	3" BRONZE CLPG
G	3" BRONZE SCREW PLUG
H	3" BRONZE RISER (1 LENGTH TO PROPER HEIGHT)
I	C.I. CAP WITH 3" TAP
J	3" BRONZE PIPE
K	PIPE CLAMP
L	CENTERING BLOCK (7.5" DIA 1 LB POWDER COATED)

NOTES:

1. FOR SIZE OF BLOW-OFF ON MAINS LARGER THAN 16", CONSULT DISTRICT ENGINEER.
2. LOWER PORTION OF 3" PIPE AND G.V. TO BE BURIED IN CONCRETE THRUST BLOCK. DO NOT BURY BONNET OF G.V. WITH CONCRETE.
3. TO BE USED ONLY AT THE DIRECTION OF DISTRICT ENGINEER.
4. COAT VALVE WITH BITUMINOUS PAINT, SEE SPECIFICATIONS.
5. RECYCLED WATER BLOW OFF ASSEMBLIES SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES AS PER SPECIFICATION SECTION IV-B1-2.06.

REV. 07/04

Dublin San Ramon Services District	DATE MAY 1987
3" BLOW-OFF ASSEMBLY AT DEAD END 10" AND 12"	DESIGNED RMR
SIGNED COPY ON FILE AT DISTRICT OFFICE	DRAWING W-10