



ITEM	DESCRIPTION
A	3" FLG G.V. WITH 2" SQ. NUT, CLOSE CLOCKWISE
B	SCREW FLANGE
C	3" BRONZE NIPPLE
D	3" BRONZE 90° ELL
E	3" BRONZE CLPG
F	3" BRONZE SCREW PLUG
G	3" BRONZE RISER (1 LENGTH TO PROPER HEIGHT)
H	MJ x MJ TO FLANGE REDUCING C.I. TEE
I	3" BRONZE PIPE TO RUN BEHIND SIDEWALK, IF APPLICABLE
J	3" FLANGED 90° OR 3" x 4" FLANGED x FLANGED REDUCING 90° ELBOW AS REQUIRED
K	THRUST BLOCK (USE THRUST BLOCK SIZE FOR 4" PIPE, DWG. W-2)
L	PIPE CLAMP
M	CENTERING BLOCK (7.5" DIA 1 LB POWDER COATED)

**NOTES:**

1. FOR SIZE OF BLOW-OFF ON MAINS LARGER THAN 16", CONSULT DISTRICT ENGINEER.
2. COAT VALVE WITH BITUMINOUS PAINT, SEE SPECIFICATIONS.
3. RECYCLED WATER BLOW OFF ASSEMBLIES SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES AS PER SPECIFICATION SECTION IV-B1-2.06.

REV. 07/04

Dublin San Ramon Services District	DATE MAY 1987
BLOW-OFF ASSEMBLY AT LOW POINT OF MAINS 6", 8", 10", 12" AND 14" MAINS	DESIGNED RMR
SIGNED COPY ON FILE AT DISTRICT OFFICE	DRAWING W-11