



NOTES

1. SECTION WITH NO. 600 CLAMP SHALL BE DUCTILE IRON WITH FLANGED ENDS.
2. DISTANCE SHALL NOT EXCEED 20 FT. AND NO SERVICE SHALL BE CONNECTED BETWEEN VALVE AND END OF WATER MAIN.
3. VALVES SHALL BE GATE VALVE FOR 6" TO 10" MAINS AND BUTTERFLY VALVES FOR 12" MAINS. VALVES SHALL HAVE RESILIAN SEATS.
4. RECYCLED WATER BLOW OFF ASSEMBLIES SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES AS PER SPECIFICATION SECTION IV-B1-2.06.
5. USE 2" BLOWOFFS FOR 6" AND 8" MAINS: USE 4" BLOWOFFS FOR 10" MAINS: USE 6" BLOWOFFS FOR 12" MAINS.
6. CENTERING BLOCK (7.5" DIA 1 LB POWDER COATED).

REV. 07/04

Dublin San Ramon Services District	DATE MAY 1987
TEMPORARY BLOWOFF FOR 12" MAINS AND SMALLER WHEN VALVE IS NOT BOLTED TO TEE OR CROSS	DESIGNED RMR
SIGNED COPY ON FILE AT DISTRICT OFFICE	DRAWING W-12