



NOTES:

1. SEE TO SECTION II-B2-10. METER BOXES, FOR METER BOX SCHEDULE
2. H2O TRAFFIC LOADING BOXES & LIDS TO BE USED IN TRAFFIC AREAS.
3. ALL METER BOXES MUST BE SET TRUE, PERPENDICULAR TO STREET, AND FLUSH WITH SIDEWALK.
4. SPACE BETWEEN BOXES IN MULTIPLE METER INSTALLATIONS SHALL BE 2".
5. DO NOT SET METER BOXES ON PRIVATE PROPERTY.
6. LID TO BE ONE PIECE, MARKED WATER, AND RADIO-READ READY.
7. IN SLOPED AREA METER BOX MAY REQUIRE REDWOOD RETAINING BOARDS.
8. UNLESS A METER BOX IS IN A SIDEWALK OR TRAFFIC AREA, THE METER BOX SHALL BE CHRISTY FIBRELYTE BOX WITH FIBRELYTE LIDS, OR APPROVED EQUAL. METER BOXES IN TRAFFIC AREAS SHALL BE CHRISTY CONCRETE METER BOX OR APPROVED EQUAL.
9. METER BOXES FOR COMMERCIAL/INDUSTRIAL BUILDINGS, OR BUILDINGS WHICH REQUIRE BACKFLOW PREVENTION DEVICES, SHALL HAVE A CONCRETE COLLAR AROUND THE METER BOX.
10. RECYCLED WATER METER BOX INSTALLATIONS SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES AS PER SPECIFICATION SECTION IV-B1-2.06.

REV.05/06

Dublin San Ramon Services District

DATE
MAY 1987

METER BOX INSTALLATIONS
5/8 INCH TO 3 INCH

DESIGNED
SAD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-19