



KEY	QTY	MATERIALS
A	1	JCM 432 ALL STAINLESS STEEL TAPPING SLEEVE, MULLER NO. H-615, OR H-19, OR APPROVED EQUAL.
B	1	4" TAPPING GATE VALVE, FLANGE BY MJ
C	1	4" DIP OR PVC
D	1	4" FLANGED COUPLING ADAPTER
E	1	4"x4" DIP ELL, FLG. x FLG.
F	1	4" DIP SPOOL, FLG. x FLG.
G	1	4" ELL, FLG. x FLG.
H	1	2" BRASS NIPPLE
I	1	2" MUELLER 300 SERIES OR EQUAL
J	1	TW#10 TRACER WIRE, EXTEND INTO METER BOX

NOTES:

1. RECYCLED WATER METER BOX INSTALLATIONS SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES AS PER SPECIFICATION SECTION IV-B1-2.06.
2. H2O TRAFFIC LOADING BOXES & LIDS TO BE USED IN TRAFFIC AREAS.
3. ALL THRUST BLOCKS TO BE POURED AGAINST UNDISTURBED SOIL.

REV. 01/07

Dublin San Ramon Services District

DATE
JULY 2000

4-INCH SERVICE W/ 2-INCH METER INSTALLATION

DESIGNED
SB

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-20A