



ITEM	DESCRIPTION
A	CORP. STOP - BRONZE (MUELLER 300 SERIES, MCDONALD 4701 BQ, OR EQUAL)
B	BRONZE COMPRESSION JOINT
C	POLYETHYLENE TUBING WITH TRACER WIRE
D	ANGLE CURB STOP, FLANGE W/WING LOCK - BRONZE (MUELLER 300 SERIES, MCDONALD 4602 BT, OR EQUAL)
E	ALL BRONZE SADDLE WITH DOUBLE STRAP (ROCKWELL 323, MUELLER 16100 SERIES, MCDONALD 3825)
F	FACE OF CURB TO BE MARKED "W"

NOTES:

1. THE SERVICE LINE SHALL REST ON UNDISTURBED EARTH IN THE BOTTOM OF THE TRENCH WITH A 36" MINIMUM COVER IN THE RUN BETWEEN THE MAIN AND THE CURB.
2. IRON SADDLES WILL NOT BE ALLOWED.
3. FOR METER INSTALLATION SEE DWG W-19.
4. METER BOXES FOR COMMERCIAL/INDUSTRIAL BUILDINGS, OR BUILDINGS WHICH REQUIRE BACKFLOW PREVENTION DEVICES, SHALL HAVE A CONCRETE COLAR AROUND THE METER BOX.
5. STAINLESS STEEL INSERT STIFFENERS SHALL BE USED AT CORP. AND ANGLE STOPS IN POLYETHYLENE SERVICE LINES WHEN RECOMMENDED BY THE FITTING MANUFACTURER.

REV. 07/09

Dublin San Ramon Services District

DATE
JUN 1983

1 1/2" - 2" SERVICE INSTALLATION

DESIGNED
SRH

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-8