



NOTES:

1. ROOF REQUIRED OVER ENTIRE ENCLOSURE WITH DOWNSPOUTS DIRECTED AWAY FROM ENCLOSURE.
2. JENSEN 320 PRECAST BOXES AS MANUFACTURED BY JENSEN PRECAST OR AN APPROVED EQUAL. ALL PIPING TO BE 4" MIN. SIZE INCLUDING INLET/OUTLET OF GREASE TRAP.
3. IF INSTALLED OUTSIDE OF ENCLOSURE, TRAFFIC RATED LID IS REQUIRED.

SCALE: N.T.S.

Dublin San Ramon Services District

REVISION DATE  
JUNE 2025

TRASH ENCLOSURE DETAIL

REVISED BY  
RM

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING  
S-12A