



Dublin San Ramon Services District

Water, wastewater, recycled water

Disclaimer for Map Requests

Dublin San Ramon Services District (DSRSD) provides the data within these pages for your personal use "as is." DSRSD gathers information from different sources and agencies to give the users a wider selection of geographic themes.

The maps shown here are for illustration purposes only and are not suitable for site-specific decision making. Information found here should not be used for making financial or any other commitments. DSRSD provides this information with the understanding that it is not guaranteed to be accurate, correct, or complete and conclusions drawn from such information are the responsibility of the user. While every effort has been made to ensure the accuracy, correctness and timeliness of materials presented anywhere within these pages, DSRSD assumes no responsibility for errors or omissions, even if DSRSD is advised of the possibility of such damage.

The data may have a number of errors which may include but are not limited to the following types of errors:

- Spatial errors - The areas depicted by these maps are approximate, and are not necessarily accurate to surveying or engineering standards. X/Y coordinates may be in error by several feet.
- Attribute errors - Database information may be incorrect.
- Currency errors - GIS data layers, databases, and documents may not be the most current available or may not depict the specified time. All data is subject to constant change. Data input lags real-world changes by varying periods of time.
- Completeness errors - Data may be missing or data may be included that does not belong.
- Projection distortion - All map projections introduce distortion by representing the irregular shape of the earth's surface on flat maps. This affects feature shapes and map distances. We choose projections which minimize these distortions when viewing most DSRSD maps.

ALL DATA IS PROVIDED AS IS.

Due to the potential that information exchanged by electronic media can deteriorate, be damaged, lost or modified unintentionally or otherwise, use of this electronic data by anyone other than dsrsd shall be at the sole risk of such user and without liability or legal exposure to DSRSD.

The foregoing warranty is exclusive and in lieu of all other warranties of merchantability, fitness for particular purpose and/or any other type whether expressed or implied. In no event shall DSRSD become liable to users of these data, or any other party, for any loss or direct, indirect, special, incidental, or consequential damages, including but not limited to time, money, or goodwill, arising from the use or modification of the data.

To assist DSRSD in the maintenance of the data, users should provide DSRSD information concerning errors or discrepancies found in using the data. If there is an E-mail contact address at the bottom of the affected web page(s), then use it. Otherwise contact:

*Dublin San Ramon Services District
Engineering Department
7051 Dublin Blvd.
Dublin, California 94568-3018
Phone: 925-828-0515
Fax: 925-829-1180
E-mail: gis@dsrsd.com*

Please acknowledge DSRSD as the source when DSRSD data are used in the preparation of reports, papers, publications, maps, or other products.

REQUESTED BY

Name: _____ Business Phone: _____

Business Name: _____

Business Address: _____

City: _____ State: _____ Zip: _____

DESCRIPTION OF MATERIAL REQUESTED

Materials Requested: _____

Material to be used for: _____

Signature: _____ Date: _____

Guidelines for Design and Construction near Dublin San Ramon Services (DSRSD) Facilities

Design

Any directional drilling or excavation within 10-feet of an existing water main or sewer main requires review by the Dublin San Ramon Services District (DSRSD) for horizontal and vertical pipeline allowable separation. Applicant shall contact DSRSD at plansubmittals@dsrsd.com.

Construction Drawings

The following DSRSD notes shall be added to your plan set.

1. Any underground installations crossing any DSRSD mains, including fire hydrant lines, water service lines and sewer laterals must meet the standard minimum clearance of 12 inches between edge of pipes. Contractor is responsible for verifying these existing utilities.
2. Installations parallel to DSRSD water, sewer and recycled water mains must have minimum separation of 6 feet from edge of pipe.
3. Notification shall be given to DSRSD inspectors (inspections@dsrsd.com) at least 72 hours before start of construction. A schedule of activities for the duration of the project must be made available at that time to facilitate the scheduling of DSRSD inspection.